

**UNIVERSITY ENGINEERING DEPARTMENT**  
Chandra Shekhar Azad University of Agriculture & Technology, Kanpur-2

No.CSAE- 548 /F.No.34/2021-22

Dated:Sept. 22 ,2021

Sealed quotations are invited by Registered/Speed Post or by Courier for the following work by 29.09.2021 before 2:00 pm. Quotation by **ORDINARY POST** or **BY HAND** will not be accepted. Blank quotation form can be taken from the Officer Incharge, University Engineering in this deptt. on any working day in office hours from 22.09.2021. Quotations will be opened on 29.09.2021 at 3:00 PM in presence of those quotationers who may like to be remain at that time.

University reserves the right to reject any or all the quotations without assigning any reason.


**Name of work: Repairing of Electric points in Textile & Clothing Deptt. at Home Science College at C.S.A.U. A& T., Kanpur**

SI No	Description of item	Qty.	Rate	Amt.
1.	Supply & Fixing of 36watt fluorescent tube light <b>Philips</b> make	10nos		
2	Supply & Fixing of 36 watt Electric choke <b>Philips</b> or <b>Havells</b> make ISI	10nos.		
3.	Supply & Fixing of 23watt 230volt LED bulb <b>Philips/Havells</b> make ISI	15nos.		
4/1203(A)	Supply & Fixing of Electronic Fan Regulator 120-280V ISI marked on the existing switch board including making connections, required material, labour T&P etc. for proper completion of work to the satisfaction of E I/C	22nos.		
5/1139	Supply & Fixing of Power Plug with 15A/250V flush type switch and 5Pin 15A/250Volt flush type universal socket in suitable M.S. Box of 175mmx100mmx50mm size with Phenolic laminated sheet cover 3mm thick fixed with brass machine screws	16nos.		
6/405	S/F of batten/Angle Holder complete in all respects	12nos.		
7/1002	S/F of 6Amp to 32Amp SPMCB (10KA) C curve	06nos.		
8/1005(B)	S/F of 63Amp DP isolator <b>Cat A</b>	02nos.		
9/1007(C)	S/F of 100Amp 4pole isolator <b>Cat A</b>	02nos.		
10	Supply & Laying of submain with 2no. 4Sq.mm PVC insulated 1100V grabe single core aluminium conductor cable in heavy duty PVC conduct with one no.2.55V mm PVC insulated Al conductor wire as earth wire complete in all respects	50meter		
11.	S/F of 6Amp F/T Switch <b>Anchor</b> make on existing switch board complete in all respects	25nos.		
12.	S/F of 6Amp F/T Socket <b>Anchor</b> make on existing switch board complete in all respects	20nos.		
13.	Rewinding of 48" ceiling fan complete in all respects	06nos.		
14/1413	S/F of LED tube light with metal heavy duty box type batten light fitting 1x22 watt suitable for upto 1x22watt LED polycarbonate tube light complete including tube complete in all respects <b>Cat AAA</b>	10nos.		

**CONDITIONS OF QUOTATIONS**

1. Rate shall be inclusive GST & other all taxes and free delivery of university campus.
2. Work shall be resumed within 05 days of the place in order and entire work to be complete within month.
3. In case of delay of work penalty upto 10% quoted cost may be imposed.
4. Quantities are liable to wide variations on either side even items may be all together omitted be compensation will be paid this account.
5. Work to be done strictly as per drawings and specifications and direction of the university Engineer.
6. Departmental Notice Board.

✓ Incharge, AKMU

  
(Naushad Khan)  
Incharge